



**Telergón, S.A.U.**  
Ctra. Castellón (Pol. La Cartuja)  
50720 La Cartuja Baja  
Zaragoza - España

Tel.: +34 976 50 08 76  
Fax: +34 976 50 03 14  
comercial@telergon.es  
www.telergon.es

**telergon**  
gorian team

**Data sheet:**  
**DC-Load break switch**  
**Model S5000 – 250A 1000V DC21B**



**Electrical data (according to IEC 60947-3)**

Thermal current I <sub>th</sub> (-30 to 50 °C)	315A
Thermal current I <sub>th</sub> (50 to 55 °C)	315A
Thermal current I <sub>th</sub> (55 to 60 °C)	315A
Thermal current I <sub>th</sub> (60 to 70 °C)	240A
Thermal current I <sub>th</sub> (70 to 80 °C)	200A
Rated insulation voltage U <sub>i</sub> (V)	1000
Rated impulse withstand voltage U <sub>imp</sub> (kV)	8

**DC Rated operational current I<sub>e</sub> (A)**

Voltage (DC)	Category of operation	I <sub>e</sub>
400 V	DC21B	315
600 V	DC21B	315
800 V	DC21B	280
900 V	DC21B	260
1000 V	DC21B	250

**Standards. IEC 60947-1&3**

**Quality Telergon, S.A.U.**

ISO 9001 & 14001	
------------------	--

**Testing as per IEC 60947-3**

Arsenal Research	 Ein Unternehmen der Austrian Research Centers
------------------	---

**Short-circuit behaviour**

Short-circuit making capacity (peak value)	I <sub>cm</sub>	20kA
Short-time withstand current (1 sec) (rms)	I <sub>ow</sub>	12kA
Conditional short-circuit current (rms value)		100kA
Maximum cut-off current (peak value)		33kA

**Connection capacity**

Bar (Thickness / Width) (mm)	7/25
Rigid cable (mm <sup>2</sup> )	185
Max. Connecting copper bar (mm)	25
Tightening torque (N·m)	18

**Mechanical data**

Minimum number of operations (as per standard) without load	20000
Maximum weight (4 pole molded case) (kg)	1,9

**Codes**


Case size (A)	Poles	Code	Code for direct handle
Size 1	4P	S5-03154PR0	DS-EI11

**Accessories:** Panel handle - DS-EN11  
Bridging links - DS-PI11  
Protective plate - DS-CU12  
Auxiliary contact - D5LAU01





Accredited by BMWA with GZ: 92714/237-IV/9/00 as test- and inspection body  
and with BGBl. II Nr. 244//2005 as certification body for personnel



# Test Report

Project Designation

PERFORMANCE OF TESTS  
ACCORDING TO  
IEC/EN 60947-1 AND IEC/EN 60947-3  
AT SWITCH-DISCONNECTORS  
TYPE S5-03154P...

Client

TELERGÓN S.A.  
Ctra. Castellón (Pol. La Cartuja)  
E-50720 La Cartuja Baja (Zaragoza)  
SPAIN

Order from / No.

12/2009 / NP07824

Project Number

2.03.02059.1.0/S5-03154P

Test Engineer

Ing.J.Ainetter

Date of issue	10.02.2010
Total number of issues / No.	1 / 1
Number of pages	7
Annex: Number of pages	---

The results relate exclusively to the terms tested.

This report may only be reproduced or published in full, without omissions, alterations or additions.

The reproduction or publishing of extracts from this report require the written approval of the research center.

## Test item

### Identification:

Switch-disconnectors type S5-03154P...

Manufacturer: TELERGÓN S.A.  
Trademark: telergon  
Rated thermal current: 315A  
Number of poles: 4  
Size: 1

## Testing location, Period of testing

### Testing location:

Österreichisches Forschungs- und Prüfzentrum Arsenal Ges.m.b.H.  
Business Unit Electric Energy Systems  
Power Service Center  
A-1210 Vienna, Giefinggasse 2  
AUSTRIA

### Period of testing:

01 ...02/2010

## Test(s)

### Test(s) performed:

Test of dielectric properties  
Test of making and breaking capacity with direct current (all poles in series)  
Test of operational performance capability with direct current (all poles in series)

### Test standard(s):

IEC 60947-1:2007 (5<sup>th</sup> Edition) and IEC 60947-3:2008 (3<sup>rd</sup> Edition)  
EN 60947-1:2007 and EN 60947-3:2009

### Test procedure(s):

CB Scheme and CCA Scheme

### Possible test case verdicts:

P (Pass): Test object does meet the requirement  
F (Fail): Test object does not meet the requirement


## Result

See page 4

## Detailed test values

See pages 5 to 7


Test Engineer



Ing. J. Ainetter



Project Engineer,  
technical responsibility



Ing. K. Farthofer

## Testing laboratory



**ACCREDITED**  
according to  
**EN ISO/IEC 17025**  
No. BMWA-92.714/0504-1/12/2007



**CERTIFICATED**  
according to  
**ISO 9001**  
Reg. No. 12769




**RECOGNIZED**  
**CB TESTING LABORATORY**  
under the responsibility of OVE  
as the National Certification Body



## POWER SERVICE CENTER:



Control station for tests up to 15kA



Control station for tests above 15kA

## Summary of test results

Dielectric properties:

- Test passed successfully at  $U_i = 1000V$

Making and breaking capacity:

- Test passed successfully at DC-21A at 1000V/250A (all poles in series)

Operational performance capability:

- Test passed successfully at DC-21A at 1000V/200A (all poles in series)
- Test passed successfully at DC-21B at 1000V/250A (all poles in series)

IEC / EN 60947-3			
Clause	Requirement - Test	Result - Remark	Verdict
8.3.3	<b>TEST SEQUENCE I: GENERAL PERFORMANCE CHARACTERISTICS</b> <b>Connection: (+) → pole 1 → pole 2 → pole 3 → Load → pole 4 → (-)</b>		P
8.3.3.2	Test of dielectric properties		P
	Rated insulation voltage $U_i$ (V) .....	1000	—
	Test voltage for 5 sec. (V).....	2200	P
	If suitable for isolation, leakage current $\leq 0,5$ mA		—
	Test voltage $1,1 U_e$ (V) .....	1100	P
	Measured leakage current (mA) .....	< 0,2	P
8.3.3.3	Making and breaking capacity		P
	- utilization category .....	DC-21A	—
	- rated operational voltage $U_e$ (V).....	1000	—
	- rated operational current $I_e$ (A).....	250	—
	Conditions for make/break operations:		P
	- test voltage, $U = 1,05 U_e$ (V) .....	1054	—
	- test current, $I = 1,5 \times I_e$ (A).....	378	—
	- time constant (ms) .....	1,08	—
	Number of make/break operations .....	5	P
	Recovery voltage duration ( $\geq 50$ ms).....	Permanent	P
	Current duration (ms).....	380	—
	Time interval between operations (s).....	30	P
8.3.3.3.5	Behaviour of the equipment during making and breaking capacity tests		P
8.3.3.3.6	Condition of the equipment after making and breaking capacity tests		P
8.3.3.4	Dielectric verification		P
	Test voltage $2 U_e$ with 1000V~ minimum (V) .....	2000	—
	No flashover or breakdown		P
8.3.3.5	Leakage current		P
	Test voltage $1,1 U_e$ (V) .....	1100	—
	Leakage current $\leq 2$ mA / pole (mA).....	< 1	P
8.3.3.6	Temperature-rise verification		P
	Test current $I_e$ (A) .....	250	—
	Cable/busbar cross-section ( $\text{mm}^2$ )/(mmxmm) .....	120 $\text{mm}^2$	—
	Temperature of main circuit terminals $\leq 80$ K (K) .....	< 55	P

IEC / EN 60947-3			
Clause	Requirement - Test	Result - Remark	Verdict
8.3.4	TEST SEQUENCE II: OPERATIONAL PERFORMANCE CAPABILITY Connection: (+) → pole 1 → pole 2 → pole 3 → Load → pole 4 → (-)		P
8.3.4.1	Operational performance capability test		P
	- utilization category .....	DC-21A	—
	- rated operational voltage U <sub>e</sub> (V).....	1000	—
	- rated operational current I <sub>e</sub> (A).....	200	—
	Test conditions for electrical operation cycles:		P
	- test voltage (V).....	1005	—
	- test current (A) .....	203	—
	- time constant (ms) .....	1,03	—
	Number of cycles with current .....	1000	P
	Number of cycles without current .....	7000	P
	First test sequence (with/without current) .....	With	—
	Second test sequence (with/without current).....	Without	—
	Time interval between first and second test sequence.....	One week	—
	Recovery voltage duration (≥ 50 ms).....	Permanent	P
	Current duration (ms).....	360	—
	Time interval between operations (s).....	30	P
8.3.4.1.5	Behaviour of the equipment during the operational performance test		P
8.3.4.1.6	Condition of the equipment after the operational performance test		P
8.3.4.2	Dielectric verification		P
	Test voltage 2 U <sub>e</sub> with 1000V~ minimum (V) .....	2000	—
	No flashover or breakdown		P
8.3.4.3	Leakage current		P
	Test voltage 1,1 U <sub>e</sub> (V).....	1100	—
	Leakage current ≤ 2 mA / pole (mA).....	< 1	P
8.3.4.4	Temperature-rise verification		P
	Test current I <sub>e</sub> (A) .....	200	—
	Cable/busbar cross-section (mm <sup>2</sup> )/(mmxmm) .....	95mm <sup>2</sup>	—
	Temperature of main circuit terminals ≤ 80 K (K) .....	< 55	P

IEC / EN 60947-3			
Clause	Requirement - Test	Result - Remark	Verdict
8.3.4	TEST SEQUENCE II: OPERATIONAL PERFORMANCE CAPABILITY Connection: (+) → pole 1 → pole 2 → pole 3 → Load → pole 4 → (-)		P
8.3.4.1	Operational performance capability test		P
	- utilization category .....	DC-21B	—
	- rated operational voltage $U_e$ (V).....	1000	—
	- rated operational current $I_e$ (A).....	250	—
	Test conditions for electrical operation cycles:		P
	- test voltage (V).....	1005	—
	- test current (A) .....	254	—
	- time constant (ms) .....	1,07	—
	Number of cycles with current .....	200	P
	Number of cycles without current .....	1400	P
	First test sequence (with/without current) .....	With	—
	Second test sequence (with/without current).....	Without	—
	Time interval between first and second test sequence.....	One week	—
	Recovery voltage duration ( $\geq 50$ ms).....	Permanent	P
	Current duration (ms).....	360	—
	Time interval between operations (s).....	30	P
8.3.4.1.5	Behaviour of the equipment during the operational performance test		P
8.3.4.1.6	Condition of the equipment after the operational performance test		P
8.3.4.2	Dielectric verification		P
	Test voltage $2 U_e$ with 1000V~ minimum (V) .....	2000	—
	No flashover or breakdown		P
8.3.4.3	Leakage current		P
	Test voltage $1,1 U_e$ (V) .....	1100	—
	Leakage current $\leq 2$ mA / pole (mA) .....	< 1	P
8.3.4.4	Temperature-rise verification		P
	Test current $I_e$ (A) .....	250	—
	Cable/busbar cross-section ( $\text{mm}^2$ )/(mmxmm) .....	120 $\text{mm}^2$	—
	Temperature of main circuit terminals $\leq 80$ K (K) .....	< 55	P